

West Robertson Water Authority Water Quality Report 2023

Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart on the back, we only detected 10 of these contaminants. We found all of these contaminants at safe levels.

What is the source of my water?

Your water, which is surface water, comes from the Red River. West Robertson Water Authority purchases water from East Montgomery Utility District, which is surface water from the Cumberland River. Our goal is to protect our water from contaminants, and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The West Robertson Water Authority sources rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System to obtain copies of specific assessments.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Jay Walker at 615-696-0667.

How can I get involved?

Our Water Board meets on the 2nd Tuesday of each month at 7pm at the WRWA Office, 604 Keysburg Rd, Adams, TN 37010. Please feel free to attend these meetings.

Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. West Robertson Water Authority's water treatment processes are designed to reduce any such substances to levels well below any health concern. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Do I Need to Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The West Robertson Water Authority is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to 615-696-0667.

Pharmaceuticals In Drinking Water

Flushing unused or expired medicines can be harmful to your drinking water. Learn more about disposing of unused medicines at <https://tdeonline.tn.gov/rxtakeback/>



Water Quality Data

What does this chart mean?

- **MCLG** - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL** - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MRDL**: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG**: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **BDL**- Below Detection Limit
- **ND**- Non Detection
- **Parts per million (ppm) or Milligrams per liter (mg/l)** – explained in terms of money as a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained in terms of money as a single penny in \$10,000,000.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **LRAA** – Locational Running Annual Average
- **TT** - Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.
- **EMUD** – Water from East Montgomery Utility District

Most of the data presented in this table is from testing done between January 1, 2023 thru December 31, 2023.

Contaminant	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria***	No	2	0	2023	ppb	0	2 positive samples	Naturally present in the environment
Turbidity ¹	No	0.19	0.01-0.19	2023	NTU	n/a	TT	Soil runoff
Turbidity ¹ EMUD	No	0.05 AVE	.04-.08	2023	NTU	n/a	TT	Soil runoff
Copper*	No	90 th %=.0104	0.001 – 0.0301	2021	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead*	No	90 th %=BDL	BDL	2021	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Atrazine	No	0.137	ND-0.137	2023	ppb	3	3	Runoff from herbicide used on row crops
Atrazine EMUD	No	ND	ND	2023	ppb	3	3	Runoff from herbicide used on row crops
Nitrate (as Nitrogen) ²	No	4.20 AVE.	3.17-5.7	2023	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (Only Required to sample once per year)	No	18.5	18.5	5-10-23	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
Sodium EMUD	No	9.93		8-8-23	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
TTHM** [Total trihalomethanes]	No	74.43 High LRAA	13.30-90.9	2023	ppb	n/a	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	No	48.97 High LRAA	2.11-46.70	2023	ppb	N/A	60	By-product of drinking water disinfection.
Total Organic Carbon ³	No	TT		2023	ppm	TT	TT	Naturally present in the environment.
Chlorine	No	1.62 AVE.	0.90-2.40	2023	ppm	MRDLG 4	MRDL 4	Water additive used to control microbes.

*During the most recent round of Lead and Copper testing, only 0 out of 20 households sampled contained concentrations exceeding the action level.
¹100% of our samples were below the turbidity limit. 100% of EMUD samples were below turbidity limit.



²Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

****Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.**

³We have met all treatment technique requirements for Total Organic Carbon removal.

*****During September 2023 and November 2023 1 of 6 routine samples test positive for total coliform. All repeat samples test negative.**

Cross-Connections

In order to maintain and protect our water system and its customers the West Robertson Water Authority takes this opportunity to inform the public about the dangers of cross-connections and how to prevent them. It is vitally important that our customers recognize and avoid cross-connections.

A cross-connection is any physical arrangement whereby a public water supply is connected, directly or indirectly, with any other water supply system; sewer, drain, conduit, pool, storage reservoir, tank, cattle trough, plumbing fixture, or other device which contains, or may contain contaminated water or other liquids of unknown or unsafe quality capable of imparting contamination to the public water supply as a result of backflow.

PLEASE BE AWARE AND CARE!

For more information about the dangers of cross-connections please call our office at (615) 696-0667.